



Figure similar

SIMATIC S7-1500F, CPU 1517F-3 PN/DP, central processing unit with work memory 3 MB for program and 8 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 3rd interface: PROFIBUS, 2 ns bit performance, SIMATIC Memory Card required

| General information                                      |   |
|--|---|
| Product type designation                                 | CPU 1517F-3 PN/DP   |
| HW functional status                                     | FS11  |
| Firmware version   | V3.1  |
| • FW update possible                                     | Yes   |
| Product function   |   |
| • I&M data   | Yes; I&M0 to I&M3   |
| • Isochronous mode                                       | Yes; Distributed and central; with minimum OB 6x cycle of 250 µs (distributed) and 1 ms (central) |
| • SysLog   | Yes   |
| Engineering with   |   |
| • STEP 7 TIA Portal configurable/integrated from version | V19 (FW V3.1); V13 Update 3 (FW V1.6) or higher   |
| Configuration control                                    |   |
| via dataset  | Yes   |
| Display  |   |
| Screen diagonal [cm]                                     | 6.1 cm  |
| Control elements   |   |
| Number of keys   | 6   |
| Mode selector switch                                     | 1   |
| Supply voltage   |   |
| Rated value (DC)   | 24 V  |
| permissible range, lower limit (DC)                      | 19.2 V  |
| permissible range, upper limit (DC)                      | 28.8 V  |
| Reverse polarity protection                              | Yes   |
| Mains buffering  |   |
| • Mains/voltage failure stored energy time               | 5 ms  |
| • Repeat rate, min.                                      | 1/s   |
| Input current  |   |
| Current consumption (rated value)                        | 1.55 A  |
| Current consumption, max.                                | 1.9 A   |
| Inrush current, max.                                     | 1.9 A; Rated value  |
| I <sub>pt</sub>  | 0.4 A <sup>2</sup> ·s   |
| Power  |   |
| Infeed power to the backplane bus                        | 12 W  |
| Power consumption from the backplane bus (balanced)      | 30 W  |
| Power loss   |   |
| Power loss, typ.   | 24 W  |
| Memory   |   |
| Number of slots for SIMATIC memory card                  | 1   |

|   |   |
|---|---|
| SIMATIC memory card required                              | Yes   |
| <b>Work memory</b>  |   |
| • integrated (for program)                                | 3 Mbyte   |
| • integrated (for data)                                   | 8 Mbyte   |
| <b>Load memory</b>  |   |
| • Plug-in (SIMATIC Memory Card), max.                     | 32 Gbyte  |
| <b>Backup</b>   |   |
| • maintenance-free  | Yes   |
| <b>CPU processing times</b>                               |   |
| for bit operations, typ.                                  | 2 ns  |
| for word operations, typ.                                 | 3 ns  |
| for fixed point arithmetic, typ.                          | 3 ns  |
| for floating point arithmetic, typ.                       | 12 ns   |
| <b>CPU-blocks</b>   |   |
| Number of elements (total)                                | 12 000; Blocks (OB, FB, FC, DB) and UDTs  |
| <b>DB</b>   |   |
| • Number range  | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999 |
| • Size, max.  | 8 Mbyte; For DBs with absolute addressing, the max. size is 64 KB   |
| <b>FB</b>   |   |
| • Number range  | 0 ... 65 535  |
| • Size, max.  | 1 Mbyte   |
| <b>FC</b>   |   |
| • Number range  | 0 ... 65 535  |
| • Size, max.  | 1 Mbyte   |
| <b>OB</b>   |   |
| • Size, max.  | 1 Mbyte   |
| • Number of free cycle OBs                                | 100   |
| • Number of time alarm OBs                                | 20  |
| • Number of delay alarm OBs                               | 20  |
| • Number of cyclic interrupt OBs                          | 20; with minimum OB 3x cycle of 100 µs  |
| • Number of process alarm OBs                             | 50  |
| • Number of DPV1 alarm OBs                                | 3   |
| • Number of isochronous mode OBs                          | 3   |
| • Number of technology synchronous alarm OBs              | 2   |
| • Number of startup OBs                                   | 100   |
| • Number of asynchronous error OBs                        | 4   |
| • Number of synchronous error OBs                         | 2   |
| • Number of diagnostic alarm OBs                          | 1   |
| <b>Nesting depth</b>                                      |   |
| • per priority class                                      | 24; Up to 8 possible for F-blocks   |
| <b>Counters, timers and their retentivity</b>             |   |
| <b>S7 counter</b>   |   |
| • Number  | 2 048   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>IEC counter</b>  |   |
| • Number  | Any (only limited by the main memory)   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>S7 times</b>   |   |
| • Number  | 2 048   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>IEC timer</b>  |   |
| • Number  | Any (only limited by the main memory)   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>Data areas and their retentivity</b>                   |   |
| Retentive data area (incl. timers, counters, flags), max. | 768 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 700 KB                           |

|  |   |
|--|---|
| Extended retentive data area (incl. timers, counters, flags), max. | 8 Mbyte; When using PS 6 0W 24/48/60 V DC HF  |
| <b>Flag</b>  |   |
| • Size, max.   | 16 kbyte  |
| • Number of clock memories   | 8; 8 clock memory bit, grouped into one clock memory byte   |
| <b>Data blocks</b>   |   |
| • Retentivity adjustable   | Yes   |
| • Retentivity preset   | No  |
| <b>Local data</b>  |   |
| • per priority class, max.   | 64 kbyte; max. 16 KB per block  |
| <b>Address area</b>  |   |
| Number of IO modules   | 16 384; max. number of modules / submodules   |
| <b>I/O address area</b>  |   |
| • Inputs   | 32 kbyte; All inputs are in the process image   |
| • Outputs  | 32 kbyte; All outputs are in the process image  |
| per integrated IO subsystem  |   |
| — Inputs (volume)  | 32 kbyte; Max. 32 KB via X1; max. 8 KB via X2 or X3   |
| — Outputs (volume)   | 32 kbyte; Max. 32 KB via X1; max. 8 KB via X2 or X3   |
| per CM/CP  |   |
| — Inputs (volume)  | 8 kbyte   |
| — Outputs (volume)   | 8 kbyte   |
| <b>Subprocess images</b>   |   |
| • Number of subprocess images, max.                                | 32  |
| <b>Hardware configuration</b>                                      |   |
| Number of distributed IO systems                                   | 64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| <b>Number of DP masters</b>  |   |
| • integrated   | 1   |
| • Via CM   | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total   |
| <b>Number of IO Controllers</b>                                    |   |
| • integrated   | 2   |
| • Via CM   | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total   |
| <b>Rack</b>  |   |
| • Modules per rack, max.   | 32; CPU + 31 modules  |
| • Number of lines, max.  | 1   |
| <b>PtP CM</b>  |   |
| • Number of PtP CMs  | the number of connectable PtP CMs is only limited by the number of available slots  |
| <b>Time of day</b>   |   |
| <b>Clock</b>   |   |
| • Type   | Hardware clock  |
| • Backup time  | 6 wk; At 40 °C ambient temperature, typically   |
| • Deviation per day, max.  | 10 s; Typ.: 2 s   |
| <b>Operating hours counter</b>                                     |   |
| • Number   | 16  |
| <b>Clock synchronization</b>                                       |   |
| • supported  | Yes   |
| • to DP, master  | Yes   |
| • on DP, device  | Yes   |
| • in AS, master  | Yes   |
| • in AS, device  | Yes   |
| • on Ethernet via NTP  | Yes   |
| <b>Interfaces</b>  |   |
| Number of PROFINET interfaces                                      | 2   |
| Number of PROFIBUS interfaces                                      | 1   |
| <b>1. Interface</b>  |   |
| <b>Interface types</b>   |   |
| • RJ 45 (Ethernet)   | Yes; X1   |
| • Number of ports  | 2   |
| • integrated switch  | Yes   |

|   |  |
|---|--|
| Protocols   |  |
| • IP protocol   | Yes; IPv4  |
| • PROFINET IO Controller  | Yes  |
| • PROFINET IO Device  | Yes  |
| • SIMATIC communication   | Yes  |
| • Open IE communication   | Yes; Optionally also encrypted   |
| • Web server  | Yes  |
| • Media redundancy  | Yes  |
| PROFINET IO Controller  |  |
| Services  |  |
| — Isochronous mode  | Yes  |
| — Direct data exchange  | Yes; Requirement: IRT and isochronous mode (MRPD optional)   |
| — IRT   | Yes  |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | Yes; Max. 32 PROFINET devices  |
| — Number of connectable IO Devices, max.                                      | 512; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| — Of which IO devices with IRT, max.  | 64   |
| — Number of connectable IO Devices for RT, max.                               | 512  |
| — of which in line, max.  | 512  |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| — PROFINET Security Class   | 1  |
| Update time for IRT   |  |
| — for send cycle of 250 µs  | 250 µs to 4 ms   |
| — for send cycle of 500 µs  | 500 µs to 8 ms   |
| — for send cycle of 1 ms  | 1 ms to 16 ms  |
| — for send cycle of 2 ms  | 2 ms to 32 ms  |
| — for send cycle of 4 ms  | 4 ms to 64 ms  |
| — With IRT and parameterization of "odd" send cycles                          | Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs)   |
| Update time for RT  |  |
| — for send cycle of 250 µs  | 250 µs to 128 ms   |
| — for send cycle of 500 µs  | 500 µs to 256 ms   |
| — for send cycle of 1 ms  | 1 ms to 512 ms   |
| — for send cycle of 2 ms  | 2 ms to 512 ms   |
| — for send cycle of 4 ms  | 4 ms to 512 ms   |
| PROFINET IO Device  |  |
| Services  |  |
| — Isochronous mode  | No   |
| — IRT   | Yes  |
| — PROFINergy  | Yes; per user program  |
| — Shared device   | Yes  |
| — Number of IO Controllers with shared device, max.                           | 4  |
| — activation/deactivation of I-devices  | Yes; per user program  |
| — Asset management record   | Yes; per user program  |
| — PROFINET Security Class   | SNMP Configuration and DCP Read Only   |
| 2. Interface  |  |
| Interface types   |  |
| • RJ 45 (Ethernet)  | Yes; X2  |
| • Number of ports   | 1  |
| • integrated switch   | No   |
| Protocols   |  |
| • IP protocol   | Yes; IPv4  |
| • PROFINET IO Controller  | Yes  |
| • PROFINET IO Device  | Yes  |
| • SIMATIC communication   | Yes  |
| • Open IE communication   | Yes; Optionally also encrypted   |

|   |  |
|---|--|
| • Web server  | Yes  |
| • Media redundancy  | No   |
| <b>PROFINET IO Controller</b>   |  |
| <b>Services</b>   |  |
| — Isochronous mode  | No   |
| — Direct data exchange  | No   |
| — IRT   | No   |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | No   |
| — Number of connectable IO Devices, max.                                      | 128; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| — Number of connectable IO Devices for RT, max.                               | 128  |
| — of which in line, max.  | 128  |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| — PROFINET Security Class   | 1  |
| <b>Update time for RT</b>   |  |
| — for send cycle of 1 ms  | 1 ms to 512 ms   |
| <b>PROFINET IO Device</b>   |  |
| <b>Services</b>   |  |
| — Isochronous mode  | No   |
| — IRT   | No   |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | No   |
| — Shared device   | Yes  |
| — Number of IO Controllers with shared device, max.                           | 4  |
| — activation/deactivation of I-devices  | Yes; per user program  |
| — Asset management record   | Yes; per user program  |
| — PROFINET Security Class   | SNMP Configuration and DCP Read Only   |
| <b>3. Interface</b>   |  |
| <b>Interface types</b>  |  |
| • RS 485  | Yes; X3  |
| • Number of ports   | 1  |
| <b>Protocols</b>  |  |
| • PROFIBUS DP master  | Yes  |
| • PROFIBUS DP device  | No   |
| • SIMATIC communication   | Yes  |
| <b>PROFIBUS DP master</b>   |  |
| • Number of connections, max.   | 48; for the integrated PROFIBUS DP interface   |
| • max. number of DP devices   | 125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| <b>Services</b>   |  |
| — Equidistance  | Yes  |
| — Isochronous mode  | Yes  |
| — activation/deactivation of DP devices                                       | Yes  |
| <b>Interface types</b>  |  |
| <b>RJ 45 (Ethernet)</b>   |  |
| • 100 Mbps  | Yes  |
| • Autonegotiation   | Yes  |
| • Autocrossing  | Yes  |
| • Industrial Ethernet status LED  | Yes  |
| <b>RS 485</b>   |  |
| • Transmission rate, max.   | 12 Mbit/s  |
| <b>Protocols</b>  |  |
| PROFIsafe   | Yes; V2.4 / V2.6   |
| <b>Number of connections</b>  |  |
| • Number of connections, max.   | 320; via integrated interfaces of the CPU and connected CPs / CMs  |
| • Number of connections reserved for ES/HMI/web                               | 10   |

|   |  |
|---|--|
| <ul style="list-style-type: none"> <li>• Number of connections via integrated interfaces</li> <li>• Number of S7 routing paths</li> </ul>   | 288<br>64; in total, only 16 S7-Routing connections are supported via PROFIBUS   |
| <b>Redundancy mode</b>  |  |
| <ul style="list-style-type: none"> <li>• H-Sync forwarding</li> </ul>   | Yes  |
| <b>Media redundancy</b>   |  |
| <ul style="list-style-type: none"> <li>— Media redundancy</li> <li>— MRP</li> <li>— MRP interconnection, supported</li> <li>— MRPD</li> <li>— Switchover time on line break, typ.</li> <li>— Number of stations in the ring, max.</li> </ul>  | only via 1st interface (X1)<br>Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client<br>Yes; as MRP ring node according to IEC 62439-2 Edition 3.0<br>Yes; Requirement: IRT<br>200 ms; For MRP, bumpless for MRPD<br>50                             |
| <b>SIMATIC communication</b>  |  |
| <ul style="list-style-type: none"> <li>• PG/OP communication</li> <li>• S7 routing</li> <li>• Data record routing</li> <li>• S7 communication, as server</li> <li>• S7 communication, as client</li> <li>• User data per job, max.</li> </ul>   | Yes; encryption with TLS V1.3 pre-selected<br>Yes<br>Yes<br>Yes<br>Yes<br>See online help (S7 communication, user data size)   |
| <b>Open IE communication</b>  |  |
| <ul style="list-style-type: none"> <li>• TCP/IP               <ul style="list-style-type: none"> <li>— Data length, max.</li> <li>— several passive connections per port, supported</li> </ul> </li> <li>• ISO-on-TCP (RFC1006)               <ul style="list-style-type: none"> <li>— Data length, max.</li> </ul> </li> <li>• UDP               <ul style="list-style-type: none"> <li>— Data length, max.</li> <li>— UDP multicast</li> </ul> </li> <li>• DHCP</li> <li>• DNS</li> <li>• SNMP</li> <li>• DCP</li> <li>• LLDP</li> <li>• Encryption</li> </ul>  | Yes<br>64 kbyte<br>Yes<br>Yes<br>64 kbyte<br>Yes<br>2 kbyte; 1 472 bytes for UDP broadcast<br>Yes; 128 multicast circuits (of which max. 5 via X1)<br>Yes<br>Yes<br>Yes<br>Yes<br>Yes<br>Yes; Optional   |
| <b>Web server</b>   |  |
| <ul style="list-style-type: none"> <li>• HTTP</li> <li>• HTTPS</li> <li>• web API               <ul style="list-style-type: none"> <li>— Number of sessions, max.</li> <li>— number of simultaneous HTTP calls, max.</li> <li>— HTTP request body, max.</li> </ul> </li> </ul>  | Yes; Standard and user pages<br>Yes; Standard and user pages<br>200<br>4<br>131 072 byte   |
| <b>OPC UA</b>   |  |
| <ul style="list-style-type: none"> <li>• Runtime license required</li> <li>• OPC UA Client               <ul style="list-style-type: none"> <li>— Application authentication</li> <li>— Security policies</li> <li>— User authentication</li> <li>— Number of connections, max.</li> <li>— Number of nodes of the client interfaces, recommended max.</li> <li>— Number of elements for one call of OPC-UA_NodeGetHandleList/OPC-UA_ReadList/OPC-UA_WriteList, max.</li> <li>— Number of elements for one call of OPC-UA_NameSpaceGetIndexList, max.</li> <li>— Number of elements for one call of OPC-UA_MethodGetHandleList, max.</li> <li>— Number of simultaneous calls of the client instructions for session management, per connection, max.</li> <li>— Number of simultaneous calls of the client instructions for data access, per connection, max.</li> <li>— Number of registerable nodes, max.</li> </ul> </li> </ul> | Yes; "Large" license required<br>Yes; Data Access (registered Read/Write), Method Call<br>Yes<br>Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256<br>"anonymous" or by user name & password<br>40<br>5 000<br>300<br>20<br>100<br>1<br>5<br>5 000 |

|  |  |
|--|--|
| — Number of registerable method calls of OPC-UA_MethodCall, max. | 100  |
| — Number of inputs/outputs when calling OPC-UA_MethodCall, max.  | 20   |
| • OPC UA Server  | Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space                   |
| — Application authentication                                     | Yes  |
| — Security policies  | available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss |
| — User authentication  | "anonymous" or by user name & password   |
| — GDS support (certificate management)                           | Yes  |
| — Number of sessions, max.                                       | 64   |
| — Number of accessible variables, max.                           | 200 000  |
| — Number of registerable nodes, max.                             | 50 000   |
| — Number of subscriptions per session, max.                      | 50   |
| — Sampling interval, min.  | 10 ms  |
| — Publishing interval, min.                                      | 10 ms  |
| — Number of server methods, max.                                 | 100  |
| — Number of inputs/outputs per server method, max.               | 20   |
| — Number of monitored items, recommended max.                    | 10 000; for 1 s sampling interval and 1 s send interval  |
| — Number of server interfaces, max.                              | 10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"                 |
| — Number of nodes for user-defined server interfaces, max.       | 30 000   |
| • Alarms and Conditions  | Yes  |
| — Number of program alarms                                       | 400  |
| — Number of alarms for system diagnostics                        | 200  |
| <b>Further protocols</b>   |  |
| • MODBUS   | Yes; MODBUS TCP  |
| <b>Isochronous mode</b>  |  |
| Equidistance   | Yes  |
| <b>S7 message functions</b>                                      |  |
| Number of login stations for message functions, max.             | 64   |
| number of subscriptions, max.                                    | 750  |
| number of tags/attributes for subscriptions, max.                | 20 000   |
| Program alarms   | Yes  |
| Number of configurable program messages, max.                    | 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH                                    |
| Number of loadable program messages in RUN, max.                 | 10 000   |
| Number of simultaneously active program alarms                   |  |
| • Number of program alarms                                       | 2 000  |
| • Number of alarms for system diagnostics                        | 1 000  |
| • Number of alarms for motion technology objects                 | 480  |
| <b>Test commissioning functions</b>                              |  |
| Joint commission (Team Engineering)                              | Yes; Parallel online access possible for up to 10 engineering systems  |
| Status block   | Yes; Up to 16 simultaneously (in total across all ES clients)  |
| Single step  | No   |
| Number of breakpoints  | 20   |
| Profiling  | No   |
| <b>Status/control</b>  |  |
| • Status/control variable  | Yes; without fail-safe   |
| • Variables  | inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters                                  |
| • Number of variables, max.                                      |  |
| — of which status variables, max.                                | 200; per job   |
| — of which control variables, max.                               | 200; per job   |
| <b>Forcing</b>   |  |
| • Forcing  | Yes; without fail-safe   |
| • Forcing, variables   | peripheral inputs/outputs (without fail-safe)  |
| • Number of variables, max.                                      | 200  |
| <b>Diagnostic buffer</b>   |  |
| • present  | Yes  |
| • Number of entries, max.  | 3 200  |

|   |   |
|---|---|
| — of which powerfail-proof  | 1 000   |
| <b>Traces</b>   |   |
| • Number of configurable Traces   | 8   |
| • Memory size per trace, max.   | 512 kbyte   |
| <b>Interrupts/diagnostics/status information</b>  |   |
| <b>Diagnostics indication LED</b>   |   |
| • RUN/STOP LED  | Yes   |
| • ERROR LED   | Yes   |
| • MAINT LED   | Yes   |
| • Connection display LINK TX/RX   | Yes   |
| <b>Supported technology objects</b>   |   |
| Motion Control  | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool |
| • Number of available Motion Control resources for technology objects                     | 10 240  |
| • Required Motion Control resources   |   |
| — per speed-controlled axis   | 40  |
| — per positioning axis  | 80  |
| — per synchronous axis  | 160   |
| — per external encoder  | 80  |
| — per output cam  | 20  |
| — per cam track   | 160   |
| — per probe   | 40  |
| • Positioning axis  |   |
| — Number of positioning axes at motion control cycle of 4 ms (typical value)              | 70  |
| — Number of positioning axes at motion control cycle of 8 ms (typical value)              | 128   |
| Controller  |   |
| • PID_Compact   | Yes; Universal PID controller with integrated optimization  |
| • PID_3Step   | Yes; PID controller with integrated optimization for valves   |
| • PID-Temp  | Yes; PID controller with integrated optimization for temperature  |
| Counting and measuring  |   |
| • High-speed counter  | Yes   |
| <b>Standards, approvals, certificates</b>   |   |
| <b>Ecological footprint</b>   |   |
| • environmental product declaration   | Yes   |
| <b>Global warming potential</b>   |   |
| — global warming potential, (total) [CO2 eq]  | 570 kg  |
| — global warming potential, (during production) [CO2 eq]                                  | 96.9 kg   |
| — global warming potential, (during operation) [CO2 eq]                                   | 483 kg  |
| — global warming potential, (after end of life cycle) [CO2 eq]                            | -9.97 kg  |
| <b>Highest safety class achievable in safety mode</b>                                     |   |
| • Performance level according to ISO 13849-1  | PLe   |
| • SIL acc. to IEC 61508   | SIL 3   |
| <b>Probability of failure (for service life of 20 years and repair time of 100 hours)</b> |   |
| — Low demand mode: PFDavg in accordance with SIL3   | < 2.00E-05  |
| — High demand/continuous mode: PFH in accordance with SIL3                                | < 1.00E-09  |
| <b>Ambient conditions</b>   |   |
| <b>Ambient temperature during operation</b>   |   |
| • horizontal installation, min.   | 0 °C  |
| • horizontal installation, max.   | 60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off                                |
| • vertical installation, min.   | 0 °C  |
| • vertical installation, max.   | 40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off                                |
| <b>Ambient temperature during storage/transportation</b>                                  |   |
| • min.  | -40 °C  |
| • max.  | 70 °C   |







[FM](#)



#### Marine / Shipping



[NK / Nippon Kaiji Ky-  
okai](#)



[CCS \(China Classifica-  
tion Society\)](#)



last modified:

4/4/2025 